

REQUEST FOR PROPOSALS

CITY OF ALEXANDRIA, LOUISIANA

D.G. HUNTER ELECTRICAL POWER PLANT  
WARTSILA OVERHAUL/MAINTENANCE SERVICES  
PHASE II – UNITS 5, 6, 7, & 8 - 2025

\*\*\*\*\*

ADDENDUM NO. 1


DATE ISSUED: THURSDAY, AUGUST 14, 2025 @ 9:30 A.M.

---

👉 **PROPOSAL DATE: TUESDAY, AUGUST 26, 2025 @ 10:00 A.M.** 👈

---

PAN AMERICAN ENGINEERS, LLC  
P.O. BOX 8599 (71306)  
1717 JACKSON STREET  
ALEXANDRIA, LOUISIANA 71301



Thomas C. David, Jr.

This addendum shall be part of the Request for Proposals (RFP) package.

This addendum is issued for the purpose of modifying and/or clarifying the Request For Proposals and is to be construed as being as much a part of the original RFP as though originally contained herein.

Acknowledge receipt of the addendum by inserting its number on Proposal Cover Sheet.

**REQUEST FOR PROPOSALS**

**SECTION VI – PROPOSAL SPECIFICATIONS**

**ITEM 1      PART 1.      INTRODUCTION**

- Delete Paragraph D. in its entirety and replace with the following:

D. With ongoing day-to-day plant operational responsibilities, the City of Alexandria does not have staffing to assist in the performance of the Overhaul Work. Accordingly, the Service Provider shall include in pricing the labor and technical resources for all Overhaul Work efforts.

**ITEM 2      PART 11.      SCOPE OF OVERHAUL/MAINTENANCE SERVICES**  
**Paragraph C.      INTERVAL: 16,000 Operating Hours**

- Insert the following:

15. Exhaust Bellows Replacement:

- a. All engine exhaust bellows, seal rings, and related bolts and nuts on each engine shall be replaced. The COA will supply the parts necessary. The Service Provider shall provide all labor associated with this work.